



# Certificate of Compliance

This certificate is issued for the following:

## Steel Pipe for Automatic Fire Sprinkler Systems

Model Easy-Flow Non-Threadable Lightwall

Sizes 1 through 5 inch NPS  
(33.7 through 139.7 mm NPS)

Sizes 1-1/4 through 4 inch NPS  
(42.4 through 114.3 mm NPS)

For use with Victaulic Co. 009N, 005H and 77 and ATUSA Empresarial S.L.U EO FN/FR and RS Grooved End Couplings

### Prepared for:

Borusan Birleşik Boru Fabrikaları Sanayi ve Ticaret A.Ş.  
Ata Mah. Sanayi Cad. No 54/68  
16601 Gemlik - Bursa,  
Türkiye

Approval Standard: FM 1630 (November 2013)

Approval Identification: 3052869  
Revision Request: RR239755

Approval Granted: 28 August 2014  
Date Authorized: 9 January 2024

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062



Member of the FM Global Group

